



中国国家强制性产品认证证书

证书编号：2025010907783226

认证委托人名称及地址

苏州明纬科技有限公司
苏州市相城区黄埭镇长平路 269 号

生产者名称及地址

明纬企业股份有限公司
新北市五股区五权三路 28 号

生产企业名称及地址

苏州明纬科技有限公司
苏州市相城区黄埭镇长平路 269 号

产品名称和系列、型号、规格

开关电源

见附页（过电压类别 III（OVC III）时，仅适用于海拔 2000m 及以下地区使用，过电压类别 II（OVC II）时，适用于海拔 5000m 及以下地区使用）

产品标准和技术要求

GB 17625.1-2022; GB 4943.1-2022; GB/T 9254.1-2021

上述产品符合《强制性产品认证实施规则 电子产品及安全附件》
（CNCA-C09-01:2023）的要求，特发此证。

发证日期：2025 年 06 月 03 日 有效期至：2030 年 06 月 02 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。

经中国合格评定国家认可委员会认可 CNAS C001-P



签发：

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号：2025010907783226

证书附页：第 1 页 共 1 页

XDR-240E-yyZZZZ (yy=12, 24, 36, 48, y 表示输出电压，影响安全和 EMC 性能； Z 可以是空白、-、0-9、a-z 或 A-Z，仅用于市场目的，不影响安全和 EMC 性能)

型号	输入规格	直流输出		变压器
		规格	直流输出范围	
XDR-240E-12ZZZZ	100-240 Vac , 2.6A , 50/60Hz	12Vdc, 20A	12-15Vdc, MAX. 240W	TF8004
XDR-240E-24ZZZZ		24Vdc, 10A	24-29Vdc, MAX. 240W	TF8005
XDR-240E-36ZZZZ		36Vdc, 6.6A	36-42Vdc, MAX. 239.76W	TF8006
XDR-240E-48ZZZZ		48Vdc, 5A	48-55Vdc, MAX. 240W	TF8007

本页为证书附页，应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2025010907783226

NAME AND ADDRESS OF THE APPLICANT
SUZHOU MEAN WELL TECHNOLOGY CO., LTD.

No.269, Changping Road, Huangdai Town, Xiangcheng District, Suzhou, Jiangsu Province, China.

NAME AND ADDRESS OF THE MANUFACTURER
MEAN WELL ENTERPRISES CO., LTD

NO.28, Wuquan 3rd Road, Wugu District, New Taipei City, Taiwan, 24891

NAME AND LOCATION OF THE FACTORY
SUZHOU MEAN WELL TECHNOLOGY CO., LTD.

No.269, Changping Road, Huangdai Town, Xiangcheng District, Suzhou, Jiangsu Province, China.

PRODUCT NAME, MODEL AND SPECIFICATION
SWITCHING POWER SUPPLY

See Appendix (Overvoltage category III (OVC III), Altitude up to 2000m, Overvoltage category II (OVC II), Altitude up to 5000m)

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS
GB 17625.1-2022; GB 4943.1-2022; GB/T 9254.1-2021

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C09-01:2023).

Valid from: Jun.03, 2025

Valid until: Jun.02, 2030

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2025010907783226

Appendix: Page 1 of 1

XDR-240E-yyZZZZ (yy=12, 24, 36, 48, y 表示输出电压，影响安全和 EMC 性能； Z 可以是空白、-、0-9、a-z 或 A-Z, 仅用于市场目的，不影响安全和 EMC 性能)

型号	输入规格	直流输出		变压器
		规格	直流输出范围	
XDR-240E-12ZZZZ	100-240 Vac , 2.6A , 50/60Hz	12Vdc, 20A	12-15Vdc, MAX. 240W	TF8004
XDR-240E-24ZZZZ		24Vdc, 10A	24-29Vdc, MAX. 240W	TF8005
XDR-240E-36ZZZZ		36Vdc, 6.6A	36-42Vdc, MAX. 239.76W	TF8006
XDR-240E-48ZZZZ		48Vdc, 5A	48-55Vdc, MAX. 240W	TF8007

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.



中国国家强制性产品认证证书

证书编号：2025010907796848

认证委托人名称及地址

苏州明纬科技有限公司
苏州市相城区黄埭镇长平路 269 号

生产者名称及地址

明纬企业股份有限公司
新北市五股区五权三路 28 号

生产企业名称及地址

明纬企业股份有限公司
新北市五股区五权三路 28 号

产品名称和系列、型号、规格

开关电源

见附页（过电压类别 III（OVC III）时，仅适用于海拔 2000m 及以下地区使用，过电压类别 II（OVC II）时，适用于海拔 5000m 及以下地区使用）

产品标准和技术要求

GB 17625.1-2022; GB 4943.1-2022; GB/T 9254.1-2021

上述产品符合《强制性产品认证实施规则 电子产品及安全附件》
（CNCA-C09-01:2023）的要求，特发此证。

发证日期：2025 年 07 月 29 日 有效期至：2030 年 07 月 28 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。

经中国合格评定国家认可委员会认可 CNAS C001-P



签发：

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号：2025010907796848

证书附页：第 1 页 共 1 页

XDR-240E-yyZZZZ (yy=12, 24, 36, 48, y 表示输出电压，影响安全和 EMC 性能； Z 可以是空白、-、0-9、a-z 或 A-Z, 仅用于市场目的，不影响安全和 EMC 性能)

型号	输入规格	直流输出		变压器
		规格	直流输出范围	
XDR-240E-12ZZZZ	100-240 Vac , 2.6A , 50/60Hz	12Vdc, 20A	12-15Vdc, MAX. 240W	TF8004
XDR-240E-24ZZZZ		24Vdc, 10A	24-29Vdc, MAX. 240W	TF8005
XDR-240E-36ZZZZ		36Vdc, 6.6A	36-42Vdc, MAX. 239.76W	TF8006
XDR-240E-48ZZZZ		48Vdc, 5A	48-55Vdc, MAX. 240W	TF8007

本页为证书附页，应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2025010907796848

NAME AND ADDRESS OF THE APPLICANT
SUZHOU MEAN WELL TECHNOLOGY CO., LTD.

No.269, Changping Road, Huangdai Town, Xiangcheng District, Suzhou, Jiangsu Province, China.

NAME AND ADDRESS OF THE MANUFACTURER
MEAN WELL ENTERPRISES CO., LTD

NO.28, Wuquan 3rd Road, Wugu District, New Taipei City, Taiwan, 24891

NAME AND LOCATION OF THE FACTORY
MEAN WELL ENTERPRISES CO., LTD

NO.28, Wuquan 3rd Road, Wugu District, New Taipei City, Taiwan, 24891

PRODUCT NAME, MODEL AND SPECIFICATION
SWITCHING POWER SUPPLY

See Appendix (Overvoltage category III (OVC III), Altitude up to 2000m, Overvoltage category II (OVC II), Altitude up to 5000m)

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS
GB 17625.1-2022; GB 4943.1-2022; GB/T 9254.1-2021

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C09-01:2023).

Valid from: Jul.29, 2025

Valid until: Jul.28, 2030

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2025010907796848

Appendix: Page 1 of 1

XDR-240E-yyZZZZ (yy=12, 24, 36, 48, y 表示输出电压，影响安全和 EMC 性能； Z 可以是空白、-、0-9、a-z 或 A-Z, 仅用于市场目的，不影响安全和 EMC 性能)

型号	输入规格	直流输出		变压器
		规格	直流输出范围	
XDR-240E-12ZZZZ	100-240 Vac , 2.6A , 50/60Hz	12Vdc, 20A	12-15Vdc, MAX. 240W	TF8004
XDR-240E-24ZZZZ		24Vdc, 10A	24-29Vdc, MAX. 240W	TF8005
XDR-240E-36ZZZZ		36Vdc, 6.66A	36-42Vdc , MAX. 239.76W	TF8006
XDR-240E-48ZZZZ		48Vdc, 5A	48-55Vdc, MAX. 240W	TF8007

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.